

Roof Fastener Spacing (feet)

Wind Speed (mph) Exposure Category	Roof Slope: 0.5:12 to 1.5:12				Roof Slope: 1.5:12 to 6:12			Roof Slope: 6:12 to 12:12		
	Thickness	Field	Edge	Corner	Field	Edge	Corner	Field	Edge	Corner
100C	26 ga	-14.1 psf 3.00	-24 psf 3.00	-36.3 psf 2.25	-12.9 psf 3.00	-22.7 psf 3.00	-33.8 psf 2.50	-14.1 psf 3.00	-16.6 psf 3.00	-16.6 psf 3.00
120C	26 ga	-20.5 psf 3.00	-34.7 psf 2.50	-52.5 psf 1.50	-18.7 psf 3.00	-32.9 psf 2.50	-48.9 psf 1.75	-20.5 psf 3.00	-24.1 psf 3.00	-24.1 psf 3.00
140C	26 ga	-28.1 psf 3.00	-47.4 psf 1.75	-71.6 psf 1.25	-25.7 psf 3.00	-45 psf 1.75	-66.8 psf 1.25	-28.1 psf 3.00	-32.9 psf 2.50	-32.9 psf 2.50
160C	26 ga	-36.8 psf 2.25	-62.1 psf 1.25	-93.7 psf 0.75	-33.7 psf 2.50	-58.9 psf 1.50	-87.4 psf 1.00	-36.8 psf 2.25	-43.1 psf 2.00	-43.1 psf 2.00
180C	26 ga	-46.7 psf 1.75	-78.7 psf 1.00	-118.7 psf 0.75	-42.7 psf 2.00	-74.7 psf 1.00	-110.7 psf 0.75	-46.7 psf 1.75	-54.7 psf 1.50	-54.7 psf 1.50
200C	26 ga	-57.8 psf 1.50	-97.3 psf 0.75	-146.6 psf 0.50	-52.8 psf 1.50	-92.3 psf 0.75	-136.8 psf 0.50	-57.8 psf 1.50	-67.7 psf 1.25	-67.7 psf 1.25
220C	26 ga	-70 psf N.G.	-117.8 psf N.G.	-177.5 psf N.G.	-64 psf 1.25	-111.8 psf 0.75	-165.6 psf 0.50	-70 psf 1.25	-82 psf 1.00	-82 psf 1.00
240C	26 ga	-83.4 psf N.G.	-140.3 psf N.G.	-211.4 psf N.G.	-76.3 psf N.G.	-133.2 psf N.G.	-197.1 psf N.G.	-83.4 psf 1.00	-97.6 psf 0.75	-97.6 psf 0.75

Notes:

1. Allowable spacing is based on the system capacity listed in the FBC 2014 Approval, FL19902.1 and determined by linear interpolation of those values. 1/3 increase is not included for wind.
2. Allowable spacing is based on an applied load determined using ASCE 7-10 for the Wind Speeds, Wind Exposure Categories, Roof Slopes and Roof Zones shown, assuming 10 square feet of tributary area, Gable roof, Enclosed building, Topographic Factor of 1, and Mean Roof Height of 25 feet.
3. Allowable spacing is determined for wind suction using the combination $0.6DL + 0.6W$. Also considered is the appropriate inward wind pressure, 20 psf live load and the weight of the panel.

N.G. indicates the panel is not recommended for this application.

- ① - FIELD
- ② - EDGE
- ③ - CORNER
- A - LEAST OF 10% MINIMUM BUILDING WIDTH OR 40% OF ROOF MEAN HEIGHT BUT NOT LESS THAN 3'-0"

