

Roof Fastener Spacing (feet)

Wind Speed (mph) Exposure Category	Roof Slope: 0.5:12 to 1.5:12				Roof Slope: 1.5:12 to 6:12			Roof Slope: 6:12 to 12:12		
	Thickness	Field	Edge	Corner	Field	Edge	Corner	Field	Edge	Corner
130D	26 ga	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00
		-28.8 psf	-48.7 psf	-73.6 psf	-26.4 psf	-46.2 psf	-68.6 psf	-28.8 psf	-33.8 psf	-33.8 psf
140D	26 ga	2.00	2.00	1.75	2.00	2.00	2.00	2.00	2.00	2.00
		-33.5 psf	-56.6 psf	-85.4 psf	-30.6 psf	-53.7 psf	-79.6 psf	-33.5 psf	-39.3 psf	-39.3 psf
150D	26 ga	2.00	2.00	1.75	2.00	2.00	1.75	2.00	2.00	2.00
		-38.6 psf	-65 psf	-98.1 psf	-35.3 psf	-61.7 psf	-91.5 psf	-38.6 psf	-45.2 psf	-45.2 psf
160D	26 ga	2.00	2.00	1.50	2.00	2.00	1.75	2.00	2.00	2.00
		-43.9 psf	-74 psf	-111.7 psf	-40.2 psf	-70.3 psf	-104.1 psf	-43.9 psf	-51.5 psf	-51.5 psf
170D	26 ga	2.00	2.00	1.50	2.00	2.00	1.50	2.00	2.00	2.00
		-49.7 psf	-83.6 psf	-126.1 psf	-45.4 psf	-79.4 psf	-117.6 psf	-49.7 psf	-58.2 psf	-58.2 psf
180D	26 ga	2.00	1.75	1.00	2.00	1.75	1.25	2.00	2.00	2.00
		-55.7 psf	-93.8 psf	-141.5 psf	-51 psf	-89.1 psf	-131.9 psf	-55.7 psf	-65.3 psf	-65.3 psf
190D	26 ga	N.G.	N.G.	N.G.	2.00	1.75	1.00	2.00	2.00	2.00
		-62.1 psf	-104.6 psf	-157.7 psf	-56.8 psf	-99.3 psf	-147.1 psf	-62.1 psf	-72.8 psf	-72.8 psf
200D	26 ga	N.G.	N.G.	N.G.	N.G.	N.G.	N.G.	2.00	2.00	2.00
		-68.9 psf	-116 psf	-174.8 psf	-63 psf	-110.1 psf	-163 psf	-68.9 psf	-80.7 psf	-80.7 psf

Notes:

- Allowable spacing is based on the system capacity listed in the FBC 2014 Approval, FL14645.2 and determined by linear interpolation of those values. 1/3 increase is not included for wind.
- Allowable spacing is based on an applied load determined using ASCE 7-10 for the Wind Speeds, Wind Exposure Categories, Roof Slopes and Roof Zones shown, assuming 10 square feet of tributary area, Gable roof, Enclosed building, Topographic Factor of 1, and Mean Roof Height of 25 feet.
- Allowable spacing is determined for wind suction using the combination $0.6DL + 0.6W$. Also considered is the appropriate inward wind pressure, 20 psf live load and the weight of the panel.

N.G. indicates the panel is not recommended for this application.

- ① - FIELD
- ② - EDGE
- ③ - CORNER
- A - LEAST OF 10% MINIMUM BUILDING WIDTH OR 40% OF ROOF MEAN HEIGHT BUT NOT LESS THAN 3'-0"

